ENVIRONMENTAL PROTECTION NOTICE

Application for a Permit under the provisions of the *Environmental Management Act*

We, Woodfibre LNG General Partner Inc, as a General Partner on behalf of the Woodfibre LNG Limited Partnership, 900-1185 West Georgia Street, Vancouver, BC, V6E 4E6, intend to submit this application to the Director to authorize the discharge of effluent (stormwater / drainage) from the Woodfibre liquefied natural gas (LNG) facility.

The Woodfibre LNG facility is located approximately seven kilometres from Squamish, British Columbia within the traditional territory of Skwxwú7mesh Úxwumixw (Squamish Nation) and səlilwətaɬ (Tsleil-Waututh Nation). The site is situated at National Topographic System (NTS) A-001-K/092-G-11 on the following fee-simple lots: District Lot 6237 Group 1 New Westminster Dist., District Lot 5899 Group 1 New Westminster Dist., District Lot 2351 Group 1 New Westminster Dist., District Lot 2802 Group 1 New Westminster Dist., District Lot 8294 Group 1 New Westminster Dist., District Lot 8295 Group 1 New Westminster Dist., and District Lot 8296 Group 1 New Westminster Dist.

Separate contact water systems for contaminated, potentially contaminated, and non-contaminated water are used to manage stormwater runoff from the site according to contaminant risk. The source of effluent is stormwater runoff and drainage water that may have come into contact with industrial infrastructure, equipment, or operational areas during LNG facility commissioning and operations. Contaminated contact water that drains from equipment areas will be collected and conveyed to an Oily Water Treatment System (OWTS) for the treatment of extractable petroleum hydrocarbons (EPH) and total suspended solids (TSS) or transported off-site for appropriate disposal. The treated effluent from the OWTS will be discharged to Howe Sound at existing Outfall 10 (OUT-10) via the non-contaminated contact water drainage system. Treated effluent from the OWTS is expected to be discharged via OUT-10 during storm events, and occasionally during dry conditions (approximately once or twice per month). During these dry periods, the discharge rate will be limited by the OWTS treated water forwarding pump capacity of 30 m^3/hr (8.3 L/s). The characteristics of the effluent are provided in the table below.

Source	Parameter	Proposed Discharge Limit
Contact Water to OUT-10	Total Suspended Solids (TSS)	25 mg/L
	Extractable Petroleum Hydrocarbons (EPH) (C10-C32)	15 mg/L

Any person may review a printed copy of the application at the Squamish Public Library or download an electronic copy of the application material from the Woodfibre LNG website at https://woodfibrelng.ca/about-woodfibre-lng/regulatory-overview/regulatory-filings/.

Any person who may be adversely affected by the proposed discharge of effluent (stormwater drainage) and wishes to provide relevant information may, within 30 days after the last date of posting, publishing, service or display, send written comments to the applicant, with a copy to Environmental Stewardship, BC Energy Regulator at 6534 100th Ave, Fort St John, BC, V1J 8C5. Comments may also be submitted to by email to the applicant (info@wlng.ca), with a copy to the BC Energy Regulator (waste.management@bc-er.ca). The identity of any respondents and the contents of anything submitted in relation to this application will become part of the public record.

Dated this 28 day of October, 2026. Marnie Gohemas

Contact person: Janine Forrest

Email address: info@wlng.ca

Phone: 1-888-801-7929