BRITISH COLUMBIA ENERGY REGULATOR

GENERAL ORDER 2026-0032-01
Amendment #1
Section 49 *Energy Resource Activities Act*

Issued to:

LNG Canada Development Inc.
4000, 500 Centre Street SE
Calgary, AB T2G 1A6

November 20, 2026

Attention: Ross Luo, Environment and Compliance Lead

Order:

Pursuant to section 49(7) of the *Energy Resource Activities Act* (the Act), I, Patrick Smook, amend General Order 2026-0032-01 issued on April 21, 2026 (the order) to LNG Canada Development Inc. (LNG Canada) as follows:

1. Beginning April 22, 2026, report to the BCER all instances of the emission of black smoke flaring that exceeds 15 minutes in duration, electronically to C&E@bc-er.ca and postpermitrequests@bc-er.ca, within 48 hours of the end of the flaring event.
2. Each report created under item 1 shall contain the Andium camera report for the period, flaring start and ending dates and times, reason for flaring, and an initial assessment of whether the black smoke event occurred during normal operations, process upset, or for emergency purposes.
3. Within 30 days of each instance of black smoke reported under item 1, submit a report completed by a Qualified Professional to the BCER that identifies the root causes of the emission of black smoke. The report must be submitted electronically to C&E@bc-er.ca and to postpermitrequests@bc-er.ca.
4. Within 60 days of submitting the report required under item 3, implement measures to prevent the emission of black smoke that addresses the root causes identified in that report. If a measure cannot reasonably be implemented within the period identified, LNG Canada must submit a report completed by a Qualified Professional to the BCER that describes the measure, any steps taken toward its implementation, the proposed implementation timeline and the reasons the additional time is required. The report must be submitted electronically to C&E@bc-er.ca and to postpermitrequests@bc-er.ca prior to the end of the 60-day period**.**
5. For the months of October 2026 through October 2028, submit a monthly report completed by a Qualified Professional that assesses the effectiveness of the measures implemented in item 4 and provides a status update on the progress in implementing any remaining measures identified in the report required under item 4 to the BCER electronically to C&E@bc-er.ca and postpermitrequests@bc-

er.ca. The monthly report must be submitted no later than 30 days following the month in which the information was collected.

Conditions:

A. This order shall remain in effect until amended or terminated in whole or in part by the BC Energy Regulator (Regulator).

Reasons:

I make this order amendment for the following reasons:

i. LNG Canada holds permit AD 100083612 as amended by AD 100106055, AD 100114004, AD 100116513 and AD 100122455.

ii. Condition 38 of the amended permit states as follows: Subject to section 18(3) of the LNGFR the Permit Holder must design, maintain and operate flares and incinerators so that flaring, other than flaring for emergency purposes, does not result in;

a) the emission of black smoke during normal operations or;

b) the emission of black smoke during process upsets that exceed a period or periods aggregating more than 15 minutes in any two hour period.

iii. On February 10-12, 2026, BCER staff conducted an inspection of LNG Canada's plant in Kitimat. During this inspection it was identified that LNG Canada had experienced emission of black smoke not in compliance with condition 38 of the permit on at least two occasions:

a. On January 6, 2026, LNG Canada had black smoke emissions during non-emergency conditions, for a period of time exceeding 7 hours.

b. On January 7, 2026, LNG Canada had black smoke emissions during non-emergency conditions, for a period of time exceeding 2 hours.

iv. Through its root cause analysis, LNG Canada identified measures to prevent black smoke. Some measures have been implemented, while the October 15, 2026 report identifies measures that are not expected to be implemented until the end of Q2 2028.

v. Reports of black smoke from LNG Canada generated since April 22, 2026 have identified a number of different causes of black smoke events. A further extension of the monitoring and reporting period is required to account for ongoing maintenance and operation of the facility over a greater period of time.

vi. I am of the opinion that LNG Canada is not in compliance with condition 38 of their amended permit.

BRITISH COLUMBIA ENERGY REGULATOR

Review or Appeal

LNG Canada may request a review of this amendment under section 70 of the Act or appeal this amendment under section 72 of the Act. Both a review and an appeal of the amendment cannot be commenced simultaneously.

A request for review may be sent to: determinationreviews@bc-er.ca.

Alternatively, a notice of appeal may be sent to the Energy Resource Appeal Tribunal info@bcerat.ca or mailed to:

Energy Resource Appeal Tribunal
PO Box 9425 Stn Prov Govt
Victoria, BC V8W 9V1

Information regarding the process for appeals may be found at www.bcerat.ca



_____

Patrick Smook
Vice President, Compliance & Operations
BC Energy Regulator

DATED AT Fort St. John, in the Province of British Columbia, this 20th day of November 2026.